

Helium Operators Familiarization Program Unit 325 – Helium Loading Scenario

Dec 2012 | Vincent HELOIN



Course Agenda

- **Loading - Scenario presentation**
- Operation Tasks and Scheduling
- Bays Repartition
- Remark on Plant Capacity – Sizing Scenario

Remark on Plant Capacity – Sizing Scenario

The Liquefier has been sized according to a loading scenario proposed by Ras Gas.


Over a Week Test, the HeRU shall be able to load 31 Trucks distributed as follows:

	Cold Clean	Warm Clean (<200ppm)	Warm Dirty (>200ppm)	Warm Load (Cold Clean)
INDEX	CC	WC	WD	WL
Number	x 24 / Week	x 6 / Week	x 1 / Week	x 7 / Week

Note:

- 4600 kg is loaded in mobile container (Tare is performed after pulling)
- Warm Trucks [WC&WD] are first Cool-Down and then sent to the parking lot for Soaking (Temp. Homogenization).
- WL Trucks are Warm Trucks returning from Soaking for Loading.
- The number of WL Trucks is equal to the total number of incoming Warm Trucks [WC+WD].

Remark on Plant Capacity – Sizing Scenario



Course Agenda

- Loading - Scenario presentation

■ Operation Tasks and Scheduling

- Loading Sequences & Main Steps
- Remark on Plant Capacity – Sizing Scenario

Operation Tasks and Scheduling - Tasks

For each task an estimation of required time has been made as following :

	Cold Clean	Warm Clean	Warm Dirty	Cold Clean (From Warm)
INDEX	CC	WC	WD	WL
IP: Initial Prep	1 h	1 h	1 h	
F: Flush (Purge)	0 h	0 h	12 h	
C: Cool-Down (300K-80K)	0 h	10 h	10 h	
K: Cool-Down (80K-4K)	2 h	2 h	2 h	
LN: LIN Filling	0 h	4 h	4 h	
S: Soaking	0 h	72 h	72 h	
LN: LIN Filling	2 h			1 h
P: Pressure Pulling	3 h			3 h
L: LOADING	6 h			6 h
X: No Activities	0 h			2 h
FP: Final Preparation	1 h	1 h	1 h	1 h
Time in Bay	15 h	18 h	30 h	13 h

Operation Tasks and Scheduling - Schedule for Week Test

CC=15h
 WC=18h
 WD=30h
 WL=13h

		BAY 1	BAY 2	BAY 3	BAY 4
1	0:00	IP2	IP1		
2	1:00	C	LN		
3	2:00	C	LN		
4	3:00	C	P		
5	4:00	C	P	IP0	
6	5:00	C	P	LN	
7	6:00	C	K	P	
8	7:00	C	K	P	
9	8:00	C	LD	LD	IP1
10	9:00	C	LD	LD	LN
11	10:00	C	LD	LD	LN
12	11:00	K	LD	LD	P
13	12:00	K	LD	LD	P
14	13:00	LN	LD	LD	P
15	14:00	LN	LD	LD	P
16	15:00	LN	IP2	X	K
17	16:00	LN	C	X	K
18	17:00	FP	C	FP	LD
19	18:00	IP0	C		LD
20	19:00	LN	C		LD
21	20:00	P	C		LD
22	21:00	P	C		LD
23	22:00	P	C		LD
24	23:00	LD	C	IP1	FP
25	00:00	LD	C	LN	
26	1:00	LD	C	LN	
27	2:00	LD	K	P	IP1
28	3:00	LD	K	P	LN
29	4:00	LD	LN	P	LN
30	5:00	X	LN	K	P
31	6:00	X	LN	K	P
32	7:00	FP	LN	P	P
33	8:00		FP	LD	K
34	9:00	IP2	IP0	LD	K
35	10:00	C	LN	LD	LD
36	11:00	C	P	LD	LD
37	12:00	C	P	LD	LD
38	13:00	C	P	FP	LD
39	14:00	C	LD		LD
40	15:00	C	LD		LD
41	16:00	C	LD	IP1	FP
42	17:00	C	LD	LN	

		BAY 1	BAY 2	BAY 3	BAY 4
43	18:00	C	LD	LN	
44	19:00	C	LD	P	
45	20:00	K	X	P	IP1
46	21:00	K	X	P	LN
47	22:00	LN	FP	K	LN
48	23:00	LN		K	P
49	00:00	LN	IP1	LD	P
50	1:00	LN	LN	LD	P
51	2:00	FP	LN	LD	K
52	3:00	IP1	P	LD	K
53	4:00	LN	P	LD	LD
54	5:00	LN	P	LD	LD
55	6:00	P	K	FP	LD
56	7:00	P	K		LD
57	8:00	P	LD	IP1	LD
58	9:00	K	LD	LN	LD
59	10:00	K	LD	LN	FP
60	11:00	LD	LD	P	
61	12:00	LD	LD	P	
62	13:00	LD	LD	P	
63	14:00	LD	FP	K	
64	15:00	LD	IP1	K	
65	16:00	LD	LN	LD	
66	17:00	FP	LN	LD	
67	18:00	IP2	P	LD	
68	19:00	C	P	LD	
69	20:00	C	P	LD	
70	21:00	C	K	LD	IP3
71	22:00	C	K	FP	P
72	23:00	C	LD	IP1	P
73	00:00	C	LD	LN	P
74	1:00	C	LD	LN	P
75	2:00	C	LD	P	P
76	3:00	C	LD	P	P
77	4:00	C	LD	P	P
78	5:00	K	FP	K	P
79	6:00	K	IP1	K	P
80	7:00	LN	LN	LD	P
81	8:00	LN	LN	LD	P
82	9:00	LN	P	LD	P
83	10:00	LN	P	LD	C
84	11:00	FP	P	LD	C


		BAY 1	BAY 2	BAY 3	BAY 4
85	12:00	IP0	K	LD	C
86	13:00	LN	K	FP	C
87	14:00	P	LD		C
88	15:00	P	LD		C
89	16:00	P	LD		C
90	17:00	LD	LD	IP1	C
91	18:00	LD	LD	LN	C
92	19:00	LD	LD	LN	C
93	20:00	LD	FP	P	K
94	21:00	LD	IP1	P	K
95	22:00	LD	LN	P	LN
96	23:00	X	LN	K	LN
97	00:00	X	P	K	LN
98	1:00	FP	P	LD	LN
99	2:00		P	LD	FP
100	3:00	IP2	K	LD	IP0
101	4:00	C	K	LD	LN
102	5:00	C	LD	LD	P
103	6:00	C	LD	LD	P
104	7:00	C	LD	FP	P
105	8:00	C	LD		LD
106	9:00	C	LD		LD
107	10:00	C	LD		LD
108	11:00	C	FP		LD
109	12:00	C	IP1		LD
110	13:00	C	LN		LD
111	14:00	K	LN		X
112	15:00	K	P		X
113	16:00	LN	P		FP
114	17:00	LN	P		IP0
115	18:00	LN	K		LN
116	19:00	LN	K	IP1	P
117	20:00	FP	LD	LN	P
118	21:00		LD	LN	P
119	22:00	IP1	LD	P	LD
120	23:00	LN	LD	P	LD
121	00:00	LN	LD	P	LD
122	1:00	P	LD	K	LD
123	2:00	P	FP	K	LD
124	3:00	P	IP1	LD	LD
125	4:00	K	LN	LD	X
126	5:00	K	LN	LD	X

		BAY 1	BAY 2	BAY 3	BAY 4
127	6:00	LD	P	LD	FP
128	7:00	LD	P	LD	IP1
129	8:00	LD	P	LD	LN
130	9:00	LD	K	FP	LN
131	10:00	LD	K		P
132	11:00	LD	LD		P
133	12:00	FP	LD	IP0	P
134	13:00	IP2	LD	LN	K
135	14:00	C	LD	P	K
136	15:00	C	LD	P	LD
137	16:00	C	LD	P	LD
138	17:00	C	FP	LD	LD
139	18:00	C	IP1	LD	LD
140	19:00	C	LN	LD	LD
141	20:00	C	LN	LD	LD
142	21:00	C	P	LD	FP
143	22:00	C	P	LD	
144	23:00	C	P	X	IP1
145	00:00	K	K	X	LN
146	1:00	K	K	FP	LN
147	2:00	LN	LD	IP1	P
148	3:00	LN	LD	LN	P
149	4:00	LN	LD	LN	P
150	5:00	LN	LD	P	K
151	6:00	FP	LD	P	K
152	7:00	IP1	LD	P	LD
153	8:00	LN	FP	K	LD
154	9:00	LN	IP1	K	LD
155	10:00	P	LN	LD	LD
156	11:00	P	LN	LD	LD
157	12:00	P	P	LD	LD
158	13:00	K	P	LD	FP
159	14:00	K	P	LD	
160	15:00	LD	K	LD	
161	16:00	LD	K	FP	
162	17:00	LD	LD		
163	18:00	LD	LD		
164	19:00	LD	LD		
165	20:00	LD	LD		
166	21:00	FP	LD		
167	22:00		LD		
168	23:00		FP		

Repartition of bays


■ Bays activities repartitions

- Loading [L]
- Cooling (300 to 80K) [C]
- Cooling (80 to 4.5K) [K]
- Other activities (LN Filling, Preparations,...) [X]



■ As loading in Dewar or mobile Dewar has a similar impact on the liquefier, the repartition could be simplified as following :

- Cooling (300 to 80K) [C]
- Cooling (80 to 4.5K) [K]
- Other activities (**Loading**, LN Filling, Preparations,...) [X]



Estimated Average Flow over a Week

	24	6	1	7
	Cold Clean	Warm Clean	Warm Dirty	Cold Clean (From Warm)
INDEX	CC	WC	WD	WL
IP: Initial Prep	1 h	1 h	1 h	
F: Flush (Purge)	0 h	0 h	12 h	
C: Cool-Down (300K-80K)	0 h	10 h	10 h	
K: Cool-Down (80K-4K)	2 h	2 h	2 h	
LN: LIN Filling	0 h	4 h	4 h	
S: Soaking	0 h	72 h	72 h	
LN: LIN Filling	2 h			1 h
P: Pressure Pulling	3 h			3 h
L: LOADING	6 h			6 h
X: No Activities	0 h			2 h
FP: Final Preparation	1 h	1 h	1 h	1 h
Time in Bay	15 h	18 h	30 h	13 h

mass		Average Flow		Average on a Week	
To Truck	From Truck	To Truck	From Truck	To Truck	From Truck
mass					
298 kg		6,9 g/s		0,5 g/s	
1320 kg	1300 kg	36,7 g/s	36,1 g/s	15,3 g/s	15,0 g/s
931 kg	180 kg	129,4 g/s	25,0 g/s	47,7 g/s	9,2 g/s
	200 kg		18,5 g/s		10,3 g/s
4800 kg	750 kg	222,2 g/s	34,7 g/s	246,0 g/s	38,4 g/s

Estimated Flow

Phase	Time	Mass	Flow
Flushing	12 hrs	300 kg	7 g/s
Pulling	3 hrs	200 kg	19 g/s
C: Cool Down (300K -> 80K) To Truck	10 hrs	1320 kg	37 g/s
C: Cool Down (300K -> 80K) From Truck	10 hrs	1300 kg	36 g/s
K: Cool Down (80K-> 4K) To Truck	2 hrs	930 kg	129 g/s
K: Cool Down (80K-> 4K) From Truck	2 hrs	180 kg	25 g/s
Soaking	1 week		
Loading To truck	6 hrs	4800 kg	222 g/s
Loading From truck	6 hrs	750 kg	35 g/s
LIN filling	2 hrs		1000 l/h

Plant Sizing

- The plant has been designed on an **average capacity**, thus the load can be higher than the plant capacity

	CXXX	XXXX	KXXX	CKXX	KKXX	
Load vs Capacity	106%	93%	97%	113%	103%	
Time repartition	37%	29%	27%	6%	1%	
Load x Time	39%	29%	26%	7%	1%	100%

- The above table shows that overload occurs during cooldown and mainly for warm mobile container.

The warmer the vapors, the higher the plant load.


- Main consequences are :

- ▣ Consumption of LHe (Decrease of Dewar Level)
- ▣ HP increases -> Excess of gas is sent to the Drum


-> Planification of Loading sequences is a key element to avoid venting gas !

-> Cooling down of mobile container has to be limited to 1 / week

CASE XXXX




CASE CXXX




C : Cool from 300 K

CASE KXXX




K : Cool from 80 K

CASE CKXX




C : Cool from 300 K K : Cool from 80 K

CASE KKXX




Helium Inventory



Helium Inventory

		BAY 1	BAY 2	BAY 3	BAY 4	Gas Bag	Drum	Storage
1	00:00	IP2	IP1			0%	3 Bara	12%
2	1:00	C	LN			10%	4 Bara	14%
3	2:00	C	LN			10%	5 Bara	16%
4	3:00	C	P			42%	6 Bara	18%
5	4:00	C	P	IP0		46%	7 Bara	20%
6	5:00	C	P	LN		51%	8 Bara	22%
7	6:00	C	K	P		55%	10 Bara	23%
8	7:00	C	K	P		59%	11 Bara	24%
9	8:00	C	LD	P		64%	12 Bara	24%
10	9:00	C	LD	LD		36%	13 Bara	23%
11	10:00	C	LD	LD	IP1	10%	14 Bara	22%
12	11:00	K	LD	LD	LN	10%	14 Bara	20%
13	12:00	K	LD	LD	P	42%	14 Bara	18%
14	13:00	LN	LD	LD	P	46%	12 Bara	17%
15	14:00	LN	LD	LD	P	51%	11 Bara	18%
16	15:00	LN	IP2	X	K	23%	11 Bara	19%
17	16:00	LN	C	X	K	10%	13 Bara	20%
18	17:00	FP	C	FP	LD	10%	14 Bara	20%
19	18:00	IP0	C		LD	10%	15 Bara	21%
20	19:00	LN	C		LD	10%	16 Bara	21%
21	20:00	P	C		LD	42%	17 Bara	22%
22	21:00	P	C		LD	46%	18 Bara	22%
23	22:00	P	C		LD	51%	19 Bara	22%
24	23:00	LD	C		IP1	23%	20 Bara	23%
25	00:00	LD	C	LN	LN	23%	20 Bara	23%
26	1:00	LD	C	LN		23%	20 Bara	23%
27	2:00	LD	K	P	IP1	27%	20 Bara	23%
28	3:00	LD	K	P	LN	32%	19 Bara	23%
29	4:00	LD	LN	P	LN	36%	18 Bara	24%
30	5:00	X	LN	K	P	40%	18 Bara	25%
31	6:00	X	LN	K	P	45%	17 Bara	26%
32	7:00	FP	LN	LD	P	49%	16 Bara	27%
33	8:00		FP	LD	K	21%	16 Bara	26%
34	9:00	IP2	IP0	LD	K	10%	16 Bara	26%
35	10:00	C	LN	LD	LD	10%	17 Bara	25%
36	11:00	C	P	LD	LD	42%	18 Bara	24%
37	12:00	C	P	LD	LD	46%	18 Bara	23%
38	13:00	C	P	FP	LD	51%	19 Bara	23%
39	14:00	C	LD		LD	51%	20 Bara	22%
40	15:00	C	LD		LD	51%	20 Bara	21%
41	16:00	C	LD	IP1	FP	51%	20 Bara	21%
42	17:00	C	LD	LN		51%	20 Bara	22%
43	18:00	C	LD	LN		51%	20 Bara	22%
44	19:00	C	LD	P		83%	20 Bara	22%
45	20:00	K	X	P	IP1	87%	20 Bara	24%
46	21:00	K	X	P	LN	91%	19 Bara	25%
47	22:00	LN	FP	K	LN	64%	19 Bara	26%



Peak due to the Pulling

When the drum reaches Pmax = 20 bars, it is discharged in the Gas Bag (323PV812).

Loading Cases Summary

	XXXX	CXXX	KXXX	CKXX	KKXX	Design
From Buffer	18,6 g/s	0,0 g/s	5,6 g/s	0,0 g/s	0,0 g/s	0,0 g/s
To Buffer	0,0 g/s	16,5 g/s	0,0 g/s	29,5 g/s	8,9 g/s	0,0 g/s
Return @ 300K	0 g/s	36 g/s	0 g/s	36 g/s	0 g/s	16 g/s
Return @ 80K	0 g/s	0 g/s	25 g/s	25 g/s	50 g/s	50 g/s
xvap	36%	37%	38%	39%	40%	37%
T6	541 g/s	541 g/s	540 g/s	538 g/s	534 g/s	540 g/s
Liq	346 g/s	340 g/s	334 g/s	328 g/s	320 g/s	340 g/s
Heat Loads	15 g/s	15 g/s	15 g/s	15 g/s	15 g/s	15 g/s
Used for Cooling (C&K)	0 g/s	37 g/s	129 g/s	166 g/s	259 g/s	62 g/s
Return from Cooling (C&K)	0 g/s	36 g/s	25 g/s	61 g/s	50 g/s	24 g/s
Liquid Filling	331 g/s	288 g/s	189 g/s	146 g/s	46 g/s	263 g/s
Rising Level	56 g/s	49 g/s	32 g/s	25 g/s	8 g/s	44,7 g/s
Dewar Return @4,5K	210 g/s	216 g/s	221 g/s	226 g/s	229 g/s	215 g/s
Loading Capacity (Net)	274 g/s	239 g/s	157 g/s	121 g/s	38 g/s	218 g/s
Mass sent L +C + K (Net)	274 g/s	240 g/s	261 g/s	226 g/s	247 g/s	256 g/s

→ The Buffer pressure evolution is a good indicator of the Liquefier Load.

Helium Losses

Design has been done to **minimize Helium Loss**.

The One week design scenario is based on “No Venting” Operation.

The following streams are returned to the gas bag:

- Truck Pressure Pulling
- Truck Flush (Purge)
- Excess of Gas returned to Drum:

To minimize He Losses during operation:

- Do not attempt to process **2 Warm Trucks** simultaneously (Drum Pressure)
- Do not attempt to **Pull 2 Trucks** Simultaneously. (Gas Bag Volume)
- Do not combine **1 Dirty Truck Flush with more than 1 pulling**. (Gas Bag Volume)